



VpCI™ ADDITIVES FOR FORMULATORS

S-7

PRODUCT DESCRIPTION

S-7 is a catalyzed sodium sulfite based oxygen scavenger designed to protect low to medium pressure boiler systems against corrosion. Oxygen present in feed water can cause severe damage to boiler equipment if left unchecked. An oxygen induced attack can lead to pitting corrosion on the metal surface, which can result in rapid failure of the boiler. Ten parts of S-7 is necessary to remove one part oxygen. It is not recommended to use S-7 in high pressure boilers.

$$(10 \times \text{Dissolved Oxygen}) + \frac{\text{Residual} \times 1.6}{\text{Feed Water Cycles}} = \text{ppm Sodium Sulfite Required}$$

FEATURES

- Economical
- Safe to use
- Easy control
- Effective against dissolved oxygen
- Compatible with other Cortec additives such as M-645
- Compatible with Cortec's corrosion inhibitors for boilers, such as VpCI-615 and VpCI-617

TYPICAL PROPERTIES

Color Off-white to tan
 Physical Form Granular powder
 pH 9.5-10.5 (1% aqueous)
 Specific gravity 2.63 @ 68F (20C)
 Solubility in water 17%
 Shelf Life up to 2 years (properly sealed container)

DOSAGE

The dosage will vary depending on the amount of dissolved oxygen in the boiler water. A starting dosage of S-7 is 100 ppm. S-7 should continue to be added until desired dissolved oxygen level is reached in the boiler water.

APPLICATION

Maximum and minimum limits are specified for control of boiler water sodium sulfite concentrations. Do not hesitate to increase or decrease the feed of this chemical, as necessary, in order to keep boiler water sulfite concentrations between the specified limits. Minimum residual levels of sodium sulfite should be between 30-60 ppm, when the boiler is operating below 150 psi. The recommended limits for sodium sulfite control are:

Boiler Pressure	Sodium Sulfite Residual
0-150 psi	30-60 ppm
150-300 psi	20-40 ppm
300-600 psi	20-30 ppm
600-900 psi	10-15 ppm
900-1200 psi	5-10 ppm
1500 psi	Sodium Sulfite Not Recommended

Test kits can be purchased from companies such as the HACH Company to monitor the level of dissolved oxygen.

FOR INDUSTRIAL USE ONLY
KEEP OUT OF REACH OF CHILDREN
KEEP CONTAINER TIGHTLY CLOSED
NOT FOR INTERNAL CONSUMPTION
CONSULT MATERIAL SAFETY DATA SHEET FOR MORE
INFORMATION

LIMITED WARRANTY

All statements, technical information and recommendations contained herein are based on tests Cortec Corporation believes to be reliable, but the accuracy or completeness thereof is not guaranteed.

Cortec Corporation warrants Cortec® products will be free from defects when shipped to customer. Cortec Corporation's obligation under this warranty shall be limited to replacement of product that proves to be defective. To obtain replacement product under this warranty, the customer must notify Cortec Corporation of the claimed defect within six months after shipment of product to customer. All freight charges for replacement products shall be paid by customer.

Cortec Corporation shall have no liability for any injury, loss or damage arising out of the use of or the inability to use the products.

BEFORE USING, USER SHALL DETERMINE THE SUITABILITY OF THE PRODUCT FOR ITS INTENDED USE, AND USER ASSUMES ALL RISK AND LIABILITY WHATSOEVER IN CONNECTION THEREWITH. No representation or recommendation not contained herein shall have any force or effect unless in a written document signed by an officer of Cortec Corporation.

THE FOREGOING WARRANTY IS EXCLUSIVE AND IN LIEU OF ALL OTHER WARRANTIES, EXPRESS, IMPLIED OR STATUTORY, INCLUDING WITHOUT LIMITATION ANY IMPLIED WARRANTY OF MERCHANTABILITY OR OF FITNESS FOR A PARTICULAR PURPOSE. IN NO CASE SHALL CORTEC CORPORATION BE LIABLE FOR INCIDENTAL OR CONSEQUENTIAL DAMAGES.



Distributed by:

4119 White Bear Parkway, St. Paul, MN 55110 USA
Phone (651) 429-1100, Fax (651) 429-1122
Toll Free (800) 4-CORTEC, E-mail info@cortecvci.com
Internet <http://www.cortecvci.com>